



This report provides only a summary of the actual survey results. Copies of the surveys have been provided to all the parties. If the Court would like further information, copies of surveys can be provided as well.

### **ACCESSIBLE POLLING PLACES**

The following polling places have been surveyed by the United States and have been determined to be accessible under the standards agreed to in this case. We indicate the ward, division, name, and entrance location of each polling place. For these polling places, the main entrance used by voters on election day is also the accessible entrance.

- Ward 1, Division 20, Office (Wharton Street)
- Ward 3, Division 18, Turner Middle School (Baltimore Avenue)
- Ward 4, Division 13, St. Matthews Manor (N. 57<sup>th</sup> Street)
- Ward 5, Division 1, Society Hill Towers Community Room (St. James Place)
- Ward 5, Division 4, Starr Garden Recreation Center (Lombard Street)
- Ward 5, Division 8, Seger Recreation Center (Lombard Street)
- Ward 11, Divisions 8, 18, Panati Recreation Center (22<sup>nd</sup> Street)
- Ward 11, Division 9, Tioga Presbyterian Senior Home (Tioga Street)
- Ward 11, Division 12, Jerome Brown Recreation Center (20<sup>th</sup> Street, up ramp)
- Ward 14, Division 4, Guild House West (Fairmont Avenue)
- Ward 14, Divisions 5, 6, Gladys Jacobs Apartment Building (Fairmont Avenue)
- Ward 15, Division 3, Roberto Clemente Recreation Center (Mt. Vernon Street)
- Ward 15, Divisions 10, 11, Francisville Recreation Center (Francis Street, through playground)
- Ward 26, Divisions 15, 18, GAMP School (Ritner Street)
- Ward 27, Division 7, Rosenberger Hall Room 100 (43<sup>rd</sup> Street)
- Ward 28, Divisions 2, 3, 6, Wright School (side entrance)

- Ward 29, Divisions 4, 7, Blumberg Senior Housing (Bolton Way)
- Ward 29, Division 5, Cecil B. Moore Library (Cecil B. Moore Avenue)
- Ward 29, Division 10, Brewerytown CDC Office (W. Master Street)
- Ward 29, Divisions 11, 13, Morris School (26<sup>th</sup> Street)
- Ward 29, Division 12, Collegeview Homes (PHA) (2 Accessible Entrances: Thompson Street and 27<sup>th</sup> Street)
- Ward 30, Divisions 5, 10, YMCA (Christian Street)
- Ward 30, Division 6, Anderson Recreation Center (17<sup>th</sup> Street)
- Ward 31, Division 5, Garage (Taggart Street)
- Ward 32, Divisions 5, 6, 8, Amos Recreation Center (16<sup>th</sup> Street)
- Ward 32, Division 7, Duckrey School (Diamond Street Visitor's Entrance)
- Ward 32, Divisions 9, 11, Carver School of Engineering and Science (Rear entrance through parking lot)
- Ward 32, Divisions 15, 16, 17, St. Elizabeth's Community Center (23<sup>rd</sup> Street into gym)
- Ward 34, Division 29, Lambert Little School (76<sup>th</sup> Street)
- Ward 34, Divisions 32, 37, 39, 41, Overbrook Library (corner of Haverford and Woodbine Avenues)
- Ward 36, Division 3, Fire Engine Company #24, (20<sup>th</sup> Street/Point Breeze)
- Ward 36, Divisions 4, 6, 7, 17, 18, 21, Wharton Square Recreation Center (3 accessible entrances: facing Reed Street, 23<sup>rd</sup> Street, Wharton Street)
- Ward 36, Divisions 12, 13, Point Breeze Court (PHA) (Dickinson Street)
- Ward 36, Division 20, Queen Memorial Library (Main Street)
- Ward 36, Division 23, New Consolation Christian Center (far end of parking lot, door leading directly into banquet facilities)
- Ward 36, Division 37, South Philadelphia Branch Library (Broad Street)

- Ward 40, Divisions 35, 45, Cibotti Recreation Center (beige double doors on 77<sup>th</sup> Street)
- Ward 40, Division 41, Residence (garage double doors on Passyunk Avenue)
- Ward 40, Division 49, Garage (74<sup>th</sup> Street bottom garage door)
- Ward 44, Divisions 1, 2, Conestoga Community Recreation Center (Media Street)
- Ward 44, Division 7, Haddington Multi Services Center (Parrish Street)
- Ward 44, Divisions 10, 13, 14, Katie Jackson Homes (PHA) (50<sup>th</sup> Street)
- Ward 44, Divisions 11, 12, Rhoads School (50<sup>th</sup> Street)
- Ward 46, Division 19, Garden Court Plaza (Pine Street)
- Ward 46, Division 23, Thrift Store (South 45<sup>th</sup> Street)
- Ward 47, Divisions 10, 13, Moore Manor Senior Home (Master Street)
- Ward 51, Division 1, Auto Garage (56<sup>th</sup> Street garage door)
- Ward 52, Division 21, Evans Recreation Center (53<sup>rd</sup> Street)
- Ward 60, Division 1, Sansom House Senior Living (Sansom Street)
- Ward 60, Divisions 3, 14, West Philadelphia Regional Library (41<sup>st</sup> & Sansom Streets)

**POLLING PLACES THAT MAY BE MADE TEMPORARILY ACCESSIBLE ON ELECTION DAY**

The following polling places have been surveyed by the United States and have been determined to be inaccessible under the standards agreed to in this case. For these polling places, there is a temporary measure(s) that may make them accessible on election day. We include the temporary measures as well as the identification of the polling places and the primary entrance. Additionally, when there is an alternate

accessible entrance, we indicate whether the accessible entrance should not be re-designated as the exclusive entrance and signs should be posted directing voters to the accessible entrance, or whether the accessible entrance should be re-designated as the exclusive entrance. If an alternate entrance is not indicated, then the primary entrance and the accessible entrance are the same entrance.

Also included in this category, are polling places that are otherwise accessible but the accessible entrance is not the primary entrance; a recommendation to re-designate the accessible entrance as the exclusive entrance is provided as a temporary remedy.

Additionally included in this category are polling places that are accessible but require signs to be posted to direct voters to an accessible entrance when it cannot be re-designated as the exclusive entrance. We include the reason why the accessible entrance should not be re-designated as the exclusive entrance.

Finally, we have included recommendations for permanent modifications for publicly-owned buildings where it may be reasonable to modify inaccessible features. Where appropriate, we have provided a recommendation as to how they may be reasonably, permanently modified to remove barriers to accessibility.

- Ward 1, Divisions 1, 9, Annunciation Church (10<sup>th</sup> Street)
  1. Move decorative table in front of call buttons at elevator to provide at least 30 inches x 48 inches clear floor space.
- Ward 1, Division 17, Heron Recreation Center (Primary Entrance: inside gate entrance at Reed Street; Accessible Entrance: sealed door next to women's toilet)
  1. Open sealed exterior door next to the women's toilet and re-designate as the exclusive entrance.

- Ward 2, Divisions 18, 22, 23, Palumbo Recreation Center (Primary Entrance: Fitzwater Street; Accessible Entrance: 10<sup>th</sup> Street)
  1. Re-designate the 10<sup>th</sup> Street entrance as the exclusive entrance.

- Ward 2, Division 25, Wallpaper Store (Passyunk Avenue)
  1. Install a temporary ramp at least 6 ½ foot long, but no longer than 7 foot long at entrance.
  2. Install a 1 inch high (12 inch long) threshold ramp at exterior entrance.
  3. Prop open door at entrance.
  
- Ward 3, Divisions 3, 4, Walnut Care Pavilion (Primary Entrance: Walnut Street; Accessible Entrance: entrance from parking lot)
  1. Re-designate entrance from the parking lot as the exclusive entrance.
  2. Create an accessible route using safety cones that runs along the right hand side of the driveway entrance to the parking area to the first vehicular access aisle on the right, and then continues to the rear entrance of the building.
  
- Ward 3, Division 10, St. George St. Barnabas Church (Primary Entrance: 61st Street; Accessible Entrance: ramped entrance on 61<sup>st</sup> Street)
  1. Re-designate ramped entrance on 61<sup>st</sup> Street as the exclusive entrance.
  2. Disable latching device by obstructing door strike on entry door or prop open entrance door.
  
- Ward 3, Divisions 12, 13, 14, Bryant School (Primary Entrance: Hazel Avenue; Accessible Entrance: Cedar Avenue)
 

Temporary Measures:

  1. Re-designate Cedar Avenue entrance as the exclusive entrance.
  2. Prop open entrance doors at Cedar Avenue.

Permanent Measures:

  1. Install compliant hardware on the exterior side of the Cedar Avenue entrance door.
  
- Ward 3, Division 17, Nixon Library (Primary Entrance: Baltimore Avenue/Cobb Street; Accessible Entrance: Baltimore Avenue)
  1. Re-designate Baltimore Avenue entrance as the exclusive entrance.
  
- Ward 4, Divisions 1, 7, Salvation Army (Arch Street Community Center Entrance)
  1. Prop open interior door to voting area.

- Ward 4, Division 2, Camphor Memorial UM Church (Primary Entrance: Wyalusing Avenue; Accessible Entrance: side of Church through parking lot)
  1. Re-designate entrance at the side of Church through parking lot as the exclusive entrance.
- Ward 4, Division 8, Mahlon Lewis Apartments (Race Street)
  1. Install 18 inch threshold ramp at building entrance.
- Ward 4, Divisions 12, 20, Mt. Caramel Baptist Church (Primary Entrance: Race Street; Accessible Entrance: Race Street)
  1. Re-designate accessible entrance on Race Street as the exclusive entrance.
- Ward 5, Division 2, Old Pine Street Community Center (Lombard Street main entrance doors)
  1. Close and do not use exterior entrance leading directly to voting area as it is not accessible.
  2. Prop open inside entry door at main entrance.
  3. Prop open interior door to voting area.
- Ward 5, Division 3, Hopkinson House (Washington Square)
  1. Have an attendant operate the elevator (up and down) on election day.
- Ward 5, Division 9, Church of St. Luke and the Epiphany (Primary Entrance: 13th Street; Accessible Entrance: ramped entrance along west side/left side with a ramp at the end)
  1. Re-designate ramped entrance along the west or left side of the Church as the exclusive entrance.
- Ward 5, Division 10, Pier 3 Penns Landing (Primary Entrance: Columbus Boulevard up main entrance; Accessible Entrance: Columbus Boulevard through parking garage)
  1. Re-designate entrance through the garage off of Columbus Boulevard as the exclusive entrance.
  2. Move the table on the interior side of the entrance door to provide at least 18 inches clearance on the side of the latch.
- Ward 5, Division 13, Chinese Church and Christian Center (Sprint Street)

1. Prop open inner vestibule doors.
- Ward 5, Division 18, Society Hill Dance Academy (Primary Entrance: 2nd Street; Accessible Entrance: down alley before the school and a left turn into the door at 401)
    1. Re-designate entrance down the alley behind the Academy to the rear entrance as the exclusive entrance.
    2. Provide a 2 inch high, 2 foot long ramp at entrance door.
    3. Prop open entrance door.
  - Ward 5, Division 21, Northern Liberties Association (Primary Entrance: corner of 3rd Street and Fairmount Avenue; Accessible Entrance: Fairmount Avenue)
    1. Re-designate Fairmount Avenue entrance as the exclusive entrance.
    2. Prop open interior door.
  - Ward 5, Division 23, Urban Defense Fitness Center (6<sup>th</sup> Street)
    1. Provide minimum 18 inch long temporary ramp to be butted up against the blue threshold at entrance door.
    2. Prop open gate at entrance.
    3. Prop open door at entrance.
    4. Provide minimum 24 inch long temporary ramp to be butted up against entry to wooden floor exercise area.
  - Ward 6, Division 6, Locke School (Haverford Street front entrance)
 

Temporary Measures:

    1. Provide a 2 foot temporary ramp at the end of the existing ramp to cover the deteriorated concrete.

Permanent Measures:

    1. Patch the deteriorated concrete ramp so that it has an even surface.
  - Ward 6, Division 10, CEP School (side entrance on Westminster Street)
    1. Provide a 12 foot long ramp from top of current interior ramp and run to the floor.
    2. Prop open interior door close to the interior ramp.

- Wards 11, 16, 28, Divisions 2, 17, 1, 18, Cecil B. Moore Recreation Center (22<sup>nd</sup> Street, Center door at top of ramp)

Temporary Measures:

1. Provide a 6 foot long temporary ramp at the six inch high step beside the short ramp facing 22<sup>nd</sup> Street.

Permanent Measures:

1. Install compliant ramp at the six inch high step beside the short ramp facing 22<sup>nd</sup> Street.

- Ward 11, Divisions 5, 6, Store (17<sup>th</sup> Street)
  1. Prop open both interior doors to the voting area.
- Ward 11, Division 10, Tioga Arms Apartments (Primary Entrance: side of building at far back; Accessible Entrance: side of building (before Primary Entrance))
  1. Post signs at front gate, at accessible entrance, and primary entrance noting where accessible entrance is.
  2. Do not re-designate accessible entrance as exclusive entrance due to an elevator at accessible entrance that cannot take heavy duty use.
  3. Prop open interior doors.
- Ward 11, Divisions 15, 16, Venango House (Primary Entrance: Venango Street; Accessible Entrance: behind building through parking lot and picnic area)
  1. Re-designate the accessible entrance as the exclusive entrance.
- Ward 11, Division 19, Woodstock Homes Community Room (Diagonally across from 2819 Lambert Street awning in courtyard)
  1. Prop open entrance door.
- Ward 14, Division 11, SBG Management Inc. (Marshall Place)
  1. Prop open interior vestibule door.
- Ward 15, Division 6, The Philadelphia Arts (Pennsylvania Avenue)
  1. Prop open interior door on route to the voting area.
  2. On election day, provide an attendant to operate the elevator.

- Ward 15, Division 7, Fire Engine Company #13 (Parrish Street)
  1. Use the left bay door as the entrance to the voting area.
  2. Keep open the left bay door (close the right bay door).
- Ward 16, Divisions 3, 4, 5, MH Stanton School (Primary Entrance: 16th Street; Accessible Entrance: Mole Street exit door)

**Temporary Measures:**

1. Re-designate the accessible entrance as the exclusive entrance.
2. Provide a 3 foot temporary ramp at Mole Street exit door.
3. Prop open Mole Street exit doors.
4. Relocate voting area to the base of the stage.
5. Move piano away from entrance at Mole Street to provide at least 36 inch wide path from the door to the voting area.

**Permanent Measures:**

1. Install a permanent, compliant ramp at the Mole Street exit door.
2. Install compliant door hardware on Mole Street exit door.

- Ward 16, Divisions 6, 9, 10, Colorado Community Center (Primary Entrance: Front of building, perpendicular to Dauphin Street; Accessible Entrance: rear of building)

**Temporary Measures:**

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open entrance door.
3. Install a line of traffic cones for 24 feet along the left side of the entrance ramp (when facing the door), providing at least a 3 foot wide path of travel that is away from the edges of the ramp where there is a dangerous drop-off.

**Permanent Measures:**

1. Change the door swing.
2. Install compliant door hardware on the exterior side of the back entrance door.
3. Install compliant handrail (dangerous drop-off on left side when facing the building).
4. Provide compliant edge protection on ramp at rear entrance (dangerous drop-off on left side when facing the building).

- Ward 24, Divisions 9, 14, Heavenly Hall (Primary Entrance: Poplar Street, double door entrance on the side of annex; Accessible Entrance: single-leaf door at the top of ramp next to the primary entrance)
  1. Re-designate the accessible entrance as the exclusive entrance.
- Ward 24, Division 10, Drexel Van Rensselaer Building (Primary Entrance: Powelton Avenue; Accessible Entrance: side of building, ramped entrance)
  1. Re-designate the accessible entrance as the exclusive entrance.
  2. Prop open interior doors leading to ballroom where voting takes place.
- Ward 26, Divisions 5, 6, 9, Barry Recreation Center (inside gate, corrugated metal door immediately beside AC unit, facing basketball courts)

Temporary Measures:

1. Provide temporary ramp at least 54 inches long at entrance. Do not use temporary wooden ramp that is used by the Recreation Center.
2. Prop open entrance door (please note that this measure was mistakenly left off the survey form, but the entrance door will need to be propped open to properly and safely use the temporary ramp).

Permanent Measures:

1. Install compliant ramp at the door beside the air conditioner in largest building on site (main entrance).
- Ward 26, Divisions 7, 8, St. Monica's Bowling Lanes (Bancroft Street)
    1. Provide 6 foot long temporary ramp for entrance at Bancroft Street.
    2. Move voting area for one division from lower level to the foyer at the entrance.
  - Ward 28, Divisions 4, 5, Strawberry Mansion School (Primary Entrance: front on Ridge Avenue; Accessible Entrance: front on Ridge Avenue at switchback ramp entrance)
    1. Re-designate the accessible entrance as the exclusive entrance.

- Ward 28, Divisions 9, 10, 11, Ethel Allen School (Primary Entrance: Rear gym doors; Accessible Entrance: Off Lehigh Avenue at visitor's entrance side of building, to the left and slightly before the main entrance (do not use the ramped door to the right of the main entrance))

Temporary Measures:

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open gym doors.

Permanent Measures:

1. Install compliant interior doors at the gym such that the clear opening width for one door is at least 32 inches.

- Wards 29, 32, Divisions 15, 4, 31, WD Kelley School (Primary Entrance: Oxford Street side door; Accessible Entrance: through playground on Marston Street)

Temporary Measures:

1. Re-designate the accessible entrance as the exclusive entrance.
2. Open gates to accessible entrance on election day.
3. Use a large rubber mat to cover deteriorating asphalt on route and before ramp to building entrance, to provide at least a 36 inch wide path of travel.

Permanent Measures:

1. Repair asphalt to provide an accessible route at least 36 inches wide.

- Ward 29, Division 8, Vaux Middle School (Primary Entrance: Masters Street; Accessible Entrance: 24<sup>th</sup> Street)

Temporary Measures:

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open door at top of exterior ramp at entrance.

Permanent Measures:

1. Relocate handrail on ramp at 24<sup>th</sup> Street entrance to provide at least 18 inches clearance to the latch side of the door.

- Ward 30, Divisions 12, 17, St. Anthony's Senior Residence (Primary Entrance: Carpenter Street; Accessible Entrance: Bonsall Street)

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open meeting room door (voting area).

- Ward 32, Division 2, F. Douglass School (Van Pelt Street)
 

Temporary Measures:

  1. Prop open interior doors.

Permanent Measures:

  1. Install compliant door hardware on interior doors.
- Ward 32, Division 10, Vernon Marks House (Clifford Street)
  1. Prop open emergency exit door.
  2. Prop open door to the voting area.
- Ward 32, Division 12, Church of the Advocate Gym (Primary Entrance: 18th Street; Accessible Entrance: Gratz Street)
  1. Re-designate the accessible entrance as the exclusive entrance.
- Ward 32, Division 19, Clara Baldwin Manor (Susquehanna Avenue)
  1. Prop open entrance door at top of ramp.
- Ward 32, Divisions 21, 23, 24, 25, Blaine School (Primary Entrance: Berks Street; Accessible Entrance: 30th Street rear entrance through the playground)
 

Temporary Measures:

  1. Re-designate the accessible entrance as the exclusive entrance.
  2. Prop open wide the 30<sup>th</sup> Street entrance doors.
  3. Prop open all interior doors (5 sets).

Permanent Measures:

  1. Install compliant doors, exterior and interior, such that one door in each set provides at least 32 inches clear passage width.
- Ward 34, Division 8, Tustin Recreation Center (Primary Entrance: off 60th Street, down stairs; Accessible Entrance: off 60th Street, through the playground)
  1. Re-designate the accessible entrance as the exclusive entrance.

- Ward 34, Divisions 17, 28, Granahan Recreation Center (off Callowhill Street facing the playground)

Temporary Measures:

1. Install 7 foot temporary ramp at step at entrance.
2. Install 1 ½ inch high and 18 inch long threshold ramp at raised threshold at entrance.
3. Prop open entrance door.

Permanent Measures:

1. Install compliant ramp (at least 7 foot long) and level landing at the exterior entrance.
2. Remove threshold and replace with threshold that is no higher than 3/4 inch at the door and is beveled on both sides.

- Ward 34, Division 21, Papa Recreation Center (Primary entrance: entrance that leads to the playground and has red bench seats next to it; Accessible Entrance: entrance leading to the parking lot)

Temporary Measures:

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open entrance door to parking lot.

Permanent Measures:

1. Install automatic door opener at entrance door leading to the parking lot.

- Ward 34, Division 26, Italian American Club (64<sup>th</sup> Street)

1. Install 1 ½ inch high and 18 inch long threshold ramp at raised threshold at entrance.
2. Prop open entrance doors.

- Ward 34, Division 31, Garage (alley/drive at rear of house, parallel with Overbrook Avenue)

1. Install 1 1/4 inch high and 15 inch long threshold ramp at garage entrance.

- Ward 36, Division 11, St. Thomas Aquinas Daycare (rear entrance by playground from alley on 17<sup>th</sup> Street)

1. Prop open exterior entry door from playground to voting area.

- Ward 36, Division 22, Vare Recreation Center (Primary entrance: 26<sup>th</sup> Street; Accessible Entrance: Moore Street playground entrance)

1. Re-designate the accessible entrance as the exclusive entrance.

- Ward 36, Divisions 26, 28, Finnegan Recreation Center (Primary entrance: Wharton Street; Accessible Entrances: side door and rear door)
  1. Re-designate the two accessible entrances as the exclusive entrances (or can select one accessible entrance exclusively).

- Ward 36, Division 29, DiSilvestro Recreation Center (15<sup>th</sup> Street)

Temporary Measures:

1. Install a 4 foot long temporary ramp at entrance door.
2. Prop open exterior entry door.

Permanent Measures:

1. Build a 4 foot long ramp and level landing at the 4 inch step on the route to the building entrance.
2. Install compliant door hardware at the building entrance.

- Ward 36, Divisions 31, 38, 41, Childs School (Dickinson & Chadwick Streets, rear entrance)

Temporary Measures:

1. Prop open exterior entrance door at the top of the ramp.
2. Install 12 foot long temporary ramp over existing ramp at exterior entrance so that the bottom of the ramp extends out further and thus reduces the slope to a compliant level.

Permanent Measures:

1. Install compliant door hardware at the exterior door at the top of the ramp.
2. Build a ramp with a compliant slope and a compliant landing at the playground entrance.

- Ward 36, Division 34, P.E.P. Building (Primary entrance: Broad Street; Accessible Entrance: Federal Street)
  1. Do not re-designate the accessible entrance as the exclusive entrance as the building has security issues with a daycare program near the accessible entrance.
  2. Post signs at the primary entrance and the accessible entrance directing voters with disabilities to the accessible entrance.

- Ward 37, Divisions 16, 19, 20, Potter Thomas School (Primary entrance: 6<sup>th</sup> Street entrance directly into gym, with step next to street; Accessible Entrance: double doors inside gate off 6<sup>th</sup> Street)

Temporary Measures:

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open one leaf of exterior double doors inside the gate.

Permanent Measures:

1. Install compliant door hardware on at least one leaf of the double doors inside of the gate.

- Ward 39, Division 16, Empty Restaurant (Porter Street)
  1. Install 2 inch high and 2 foot long temporary threshold ramp at exterior entry marble threshold.
- Ward 39, Divisions 17, 22, Taggart School (Porter Street)
  1. Prop open inner vestibule doors.
  2. Remove astragal at inner vestibule doors.
  3. Prop open both interior doors to the room housing the voting area.
- Ward 39, Division 34, Magic Auto Detailing (1032 Cantrell Street)
  1. Install at least a 54 inch long temporary ramp at Cantrell Street overhead garage door entrance.
- Ward 39, Division 42, Jenks School Trailer (schoolyard at Jenks School)

Temporary Measures:

1. Add 1 inch high and 12 inch long temporary threshold ramp to the bottom of the existing ramp.
2. Prop open exterior door at the top of the existing ramp.

Permanent Measures:

1. Install another piece of wood to the bottom of the existing exterior ramp so that it reaches the concrete surface of the schoolyard.
2. Install compliant door hardware at the building entrance at the top of the ramp.

- Ward 40, Divisions 1, 6, 12, 13, 14,15, 16, 18, 28, Morton School (Primary entrance: Dickinson Street; Accessible Entrance: visitor entrance to school)

**Temporary Measures:**

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open both leaves of exterior double doors at visitor entrance.
3. Prop open both leaves of interior vestibule doors at visitor entrance.
4. Remove astragal at interior vestibule doors at visitor entrance.
5. Prop open both leaves of interior doors in hallway leading to the gym from the visitor entrance.
6. Prop open both doors to the gym.

**Permanent Measures:**

1. Install compliant doors at visitor entrance, with one door having at least 32 inches of clear passage width.
2. Install compliant doors in hallway leading to the gym from the visitor entrance, with one door having at least 32 inches of clear passage width.
3. Install compliant doors at the interior doors to the gym (from the interior hallway leading from the visitor entrance), with one door having at least 32 inches of clear passage width.

- Ward 40, Divisions 11, 26, Catharine School Annex (Primary entrance: Greenway Avenue; Accessible Entrance: direct exterior entrance to Room 213)

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open exterior door leading directly to Room 213.

- Ward 40, Divisions 36, 48, Eastwick Library (green double doors to the right of the main entrance)

**Temporary Measures:**

1. Install 6 foot long temporary ramp in parking lot at closest possible location to green double-doors at voting area entrance.
2. Prop open interior door to the voting area.

**Permanent Measures:**

1. Build a compliant curb ramp or curb cut (with a compliant slope and no abrupt level changes over ½ inch) from the parking lot to the sidewalk.

- Ward 40, Division 37, Residence (lower level with sliding glass doors on Dickens Place)
  1. Install 1 inch high and 12 inch long temporary threshold ramp at exterior of sliding glass doors.
  2. Install 1 3/4 inch high and 21 inch long temporary threshold ramp at interior of sliding glass doors.
- Ward 40, Division 50, Unico Village Office (Vastola Hall)
  1. Prop open exterior entrance doors at Vastola Hall.
- Ward 46, Division 3, Storefront (52<sup>nd</sup> Street)
  1. Install 6 foot long temporary ramp at exterior entrance.
  2. Prop open exterior entrance door.
- Ward 46, Division 8, Park Pleasant Nursing Home (Primary entrance: Kingsessing Avenue porch entrance; Accessible Entrance: Door 17 delivery entrance)
  1. Re-designate the accessible entrance as the exclusive entrance.
  2. Prop open Door 17.
  3. Prop open interior door connecting meeting room (voting area) to hallway.
- Ward 47, Division 6, North Philadelphia 7<sup>th</sup> Day Adventist (Primary entrance: Oxford Street; Accessible Entrance: Oxford & Sydenham Streets)
  1. Re-designate the accessible entrance as the exclusive entrance.
- Ward 48, Divisions 2, 3, 5, 6, Dixon House Community Center (Primary entrance: 20<sup>th</sup> Street left entrance; Accessible Entrance: 20<sup>th</sup> Street main building entrance)
  1. Re-designate the accessible entrance as the exclusive entrance.
- Ward 48, Division 10, Cement Masons Training Center (Snyder Avenue)
  1. Install a mat or 1 inch high and 12 inch long threshold ramp for 1 inch lip at base of curb ramp to exterior entrance door.
  2. Install 8 foot long plate or flat ramp over unfinished walkway.

- Ward 48, Divisions 14, 20, St. Agnes Continuing Care Center (Broad Street)
  1. Prop open interior doors.
  2. Remove astragal.
  3. Prop open both interior doors to the voting area.
  4. Remove astragal in doors to the voting area.
- Ward 51, Divisions 12, 13, 20, Shaw Middle School (Primary entrances: (1) Warrington Street; (2) 55<sup>th</sup> & Warrington Streets; (3) 54<sup>th</sup> & Warrington Streets; Accessible Entrance: 54<sup>th</sup> & Warrington Streets)

**Temporary Measures:**

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open both exterior entrance doors at 54<sup>th</sup> Street.
3. Remove astragal at 54<sup>th</sup> Street entrance.

**Permanent Measures:**

1. Install compliant doors at 54<sup>th</sup> Street entrance, with one door having at least 32 inches of clear passage width.

- Ward 51, Division 14, Fire Engine Company #68 (52<sup>nd</sup> Street)
  1. Designate the bay door entrance farthest to the right when facing the building, as the entrance to the voting area.
- Ward 51, Division 15, Harrington School (Primary entrances: (1) Baltimore Avenue; (2) Angorra Street; Accessible Entrance: Baltimore Avenue)

**Temporary Measures:**

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open both exterior entrance doors at Baltimore Avenue.
3. Remove astragal at exterior entrance doors at Baltimore Avenue.

**Permanent Measures:**

1. Install compliant doors at building entrance on Baltimore Avenue, with one door having at least 32 inches of clear passage width.

- Ward 51, Divisions 21, 25, Charter School (56<sup>th</sup> Street)

Temporary Measures:

1. Install 6 foot long temporary ramp at 56<sup>th</sup> Street entrance.
2. Prop open 56<sup>th</sup> Street entrance door.
3. Do not use the temporary ramp that is used by the school.

Permanent Measures:

1. Extend the step located on the route to the building entrance in order to create a landing.
2. Build a curb ramp at the step located on the route to the building entrance.
3. Install compliant door hardware at the building entrance.

- Ward 52, Division 18, St. Barbara's Church (Primary entrance: Lebanon Avenue, multiple red doors facing street with staircase; Accessible Entrance: backside entrance at single red door without a step)

1. Because of church security issues, do not re-designate the accessible entrance as the exclusive entrance.
2. Provide signs at the primary entrance and the accessible entrance directing voters with disabilities to the accessible entrance.
3. Because the exterior doors cannot be propped open, station an attendant at rear exterior church door during voting hours to open exterior doors.
4. Prop open both leaves of inner church doors at entrance.
5. There are two pairs of double doors to the inner church that cannot be propped open; have attendant at exterior entrance open these doors as well.

- Ward 52, Divisions 20, 26, 27, Beeber Middle School (Primary entrance: 59<sup>th</sup> Street; Accessible Entrance: 59th Street with ramp)

Temporary Measures:

1. Re-designate the accessible entrance as the exclusive entrance.
2. Prop open exterior entrance doors.
3. Prop open Administrative Office door (one of three voting areas).
4. To provide edge protection, use a 1 inch x 4 inch piece of wood (or similar material), along the entire length of the ramp, with plastic ties to secure to the vertical components of the railing of the exterior ramp.

Permanent Measures:

1. Install compliant hardware on exterior entrance door.
2. Install a continuous metal bar along the entire length of the ramp so as to provide permanent edge protection.

- Ward 52, Division 25, Church Office (56<sup>th</sup> Street door with 5478 atop it)

1. Prop open exterior door with 5478 atop it.
2. Prop open interior door to voting area.

- Ward 60, Division 7, Sayre School (Walnut Street)

Temporary Measures:

1. Remove astragal from at least one set of exterior double doors at Walnut Street entrance.

Permanent Measures:

1. Install compliant doors at exterior building entrance, with one door having at least 32 inches of clear passage width.

- Ward 60, Division 13, Barber Shop (52<sup>nd</sup> Street)

1. Install a 5 foot long temporary ramp at the entrance.
2. Prop open exterior entrance door.

- Ward 60, Divisions 21, 22, Morris Recreation Center (Primary entrance: Spruce Street; Accessible Entrance: in the rear of the building through the parking lot from the 58<sup>th</sup> Street & 59<sup>th</sup> Street gates)

Temporary Measures:

1. Re-designate the accessible entrance as the exclusive entrance.
2. Because access is behind the building through schoolyard gates off of 58<sup>th</sup> and 59<sup>th</sup> Streets, we suggest posting signs and directions at the gates through the parking lot and at the rear of the building.
3. Open 58<sup>th</sup>/59<sup>th</sup> Street gates.

Permanent Measures:

1. Re-grade existing walkway to provide compliant slope.

Respectfully Submitted,

ELIZABETH JOHNSON  
Senior Trial Attorney  
Civil Rights Division  
950 Pennsylvania Avenue, N.W.  
Disability Rights Section - NYA  
Washington, DC 20530

JOHN L. WODATCH, Chief

ALLISON NICHOL, Deputy Chief  
PHILIP L. BREEN, Special Legal Counsel  
ALBERTO RUISANCHEZ, Trial Attorney  
U.S. Department of Justice  
Civil Rights Division  
950 Pennsylvania Avenue, N.W.  
Disability Rights Section - NYA  
Washington, DC 20530

Dated: October 30, 2009